# Multi-Model Based Incident Prediction and Risk Assessment in Dynamic Cybersecurity Protection for Industrial Control Systems

**Zhang Qi** qiqi@hust.edu.cn

October 13, 2015



Automation School, Huazhong University of Science and Technology, Wuhan.

#### **Outlines**

Introduction

Architecture

**Hazardous Incident Prediction** 

The Bayesian Network Based Knowledge Modeling

**Incident Prediction** 

Dynamic Risk Assessment

**Decouple of Incident Consequences** 

Classification of Incident Consequences

Quantification of Incident Consequences

Calculation of Dynamic Risk

Simulation

Simulation Platform

Simulation and Result Analysis

Conclusion and Prospect


Conclusion

Prospect



## **Background**

Driven by computer technology, communication technology and intellectual technology, Industrial Control Systems (ICSs) develop towards the direction of intellectualization and network.




## **Background**

- ICSs have been widely applied in various industry of the national economy and people's livelihood, and gradually become
  the brain and central nervous of critical infrastructure and all
  kinds of industrial production.
- Once abnormal situation appears in ICSs, serious accidents may be happen, which may cause damage to property, people or a wide range of environment.



## **Background**

- In 2010, Stuxnet attacked Iran's nuclear power plants and ruined almost one-fifth of Iran's nuclear centrifuges.
- In 2013, Israel Haifa highway control system was attacked by hackers, which caused massive traffic congestion in the city which lead great loss and serious subsequent problems.
- In 2014, Havex malware infects many industrial control system in European and caused the leakage of large amounts of data.





## **Problems – Timeliness and Availability**

ICSs have rigorous requirements on timeliness and availability. The cybersecurity risks of ICSs are primarily from the potential loss caused by the cyber-attacks which demolish the timeliness and availability of the control system.

In order to achieve the destructive purpose, attackers generally need to follow part or all of these three steps:

- 1. infiltrate into the field network,
- 2. invalidate the system functions,
- 3. cause the hazardous incidents.

Therefore, the cybersecurity risk assessment of ICSs needs a novel and targeted risk model to analyze the risk propagation.

## **Problems – Overlapping amongst Consequences**

The majority of existing quantitative risk assessment approaches used the following definition to calculate the risk  $\mathcal{R}$ .

$$\mathcal{R} = \sum_{i} S(e_i) P(e_i)$$

However, the overlapping amongst difference consequences may cause the error of risk value. For example,



incident  $e_1$  is the temperature anomaly of reactor, incident  $e_2$  is the explosion of reactor, when  $e_1$  or  $e_2$  happens, the product will be damaged.

Assume that  $P(e_1) = 1$ , so  $P(e_2) = p_1$ , then

$$\mathscr{R} = S(e_1) + p_1 S(e_2) = S(e_1) + p_1 S(e_1) = (1 + p_1) S(e_1) \ge S(e_1).$$

#### **Problems – Unknown Attacks**


Many ICSs run 24/7/365, and therefore the updates must be planned and scheduled days or weeks in advance. After the updates, exhaustive testing is necessary to ensure the high availability of the ICS.

This leads to inability of the attack knowledge of ICSs to be updated in time. Several attack knowledge-based risk assessments cannot work well on ICSs.

Therefore, the risk assessment should have the ability of assessing the risk caused by unknown attacks without the corresponding attack knowledge.




## **Architecture of Cybersecurity Risk Assessment for ICSs**




# Hazardous Incident Prediction

#### **Attack Level**

In this paper, the Bayesian network is used to model the relationship between attacks and resources.




Function Tree Analysis is widely used to analyze the stability of control system, a typical function tree is shown in following figure.




$$F_1 = F_2 F_3 F_4 F_5$$

Function Tree Analysis is widely used to analyze the stability of control system, a typical function tree is shown in following figure.




$$F_2 = F_6 F_7 \overline{F_8} F_9$$

Function Tree Analysis is widely used to analyze the stability of control system, a typical function tree is shown in following figure.




$$F_5 = F_{10} + F_{11} + F_{12} + F_{13}$$


To simplify the inference, the function tree is converted into Bayesian network, which is shown in following figure.




To simplify the inference, the function tree is converted into Bayesian network, which is shown in following figure.




To simplify the inference, the function tree is converted into Bayesian network, which is shown in following figure.






The conditional probability table of the Bayesian network contains more information than the logical gate of the fault tree.



#### **Incident Level**

The occurrence of one incident may cause another incidents, in this paper, the Bayesian network is also used to model the causal relationship amongst the potential incidents.


A typical Bayesian network of incident is shown in following figure.



#### **Information Transfer between Levels**

The cyber attacks can lead to system function failures, and the function failures may cause the industrial incidents. To analyze the risk propagation, an information transfer is necessary between the three aforementioned layers.


The following figures show two kind of information transfer.



#### **Information Transfer between Levels**

The cyber attacks can lead to system function failures, and the function failures may cause the industrial incidents. To analyze the risk propagation, an information transfer is necessary between the three aforementioned layers.

The following figures show two kind of information transfer.




#### **Collection of Evidence**

There are two kind of evidence need to be collected:

- **Attack Evidence**, contains the attack information, such as attack time, attack type, attack object, etc.
- Anomaly Evidence, contains the information about the anomaly, such as function failure, function restoration, incident occurrence, etc.

For each evidence, there exists a corresponding node in the multilevel Bayesian network. When the intrusion detection system or the monitoring system finds an evidence, the corresponding node will be marked in the multi-level Bayesian network.

## **Calculation of Incident Probability**



The left figure shows a typical multi-level Bayesian network.

Assuming that the evidence list is

$$a_1, a_6, f_1$$

Then the nodes  $a_1$ ,  $a_6$ , and  $f_1$  are marked with **red** dashed circles.

Finally, the algorithm named Probability Propagation in Trees of Clusters (PPTC) can calculate the probabilities of all the hazardous incidents.

# Dynamic Risk Assessment

for each incident  $e_i$ , analyze its consequence and generate a consequence set

$$\boldsymbol{c}_i = (c_1, c_2, \cdots, c_n).$$

The meaning of  $c_i$  is that the occurring of the incident  $e_i$  will threaten the elements in consequence set  $c_i$ .

For example, the incident  $e_i$  is an explosion of a reactor, which may cause worker casualties, air pollution, facilities damages, and products loss. The consequence set of  $e_i$  is

 $c_i = (workers, air, facilities, products).$ 

For each  $c'_j \in C'$ , generate a corresponding auxiliary node  $x_j$ . According to the **traceability** of C'

$$\forall c' \in C', \exists c \in C, c' \subseteq c,$$

there must be a consequence set  $c_i \in C$ , where  $c_j' \subseteq c_i$ . So, for each  $c_i' \in C'$ , we can find the incident set

$$\boldsymbol{e}_j=(e_{i_1},e_{i_2},\cdots,e_{i_n}).$$

For each incident  $e_k$  of the incident set  $e_j$ , the corresponding consequence set  $c_k$  satisfies the following condition:

$$c'_j \subseteq c_k$$
.

Therefore, the parent nodes of the auxiliary node  $x_j$  are incident nodes  $e_{i_1}, e_{i_2}, \dots, e_{i_m}$ .

For each auxiliary node  $x_j$ , generate a conditional probability table. A typical conditional probability table of auxiliary node  $x_j$  is shown as following table.

$H(e_{i_1})$	Т	T	Т		F	F	F
$H(e_{i_2})$	Т	T	T		F	F	F
$H(e_{i_3})$	Т	T	T		F	F	F
÷	:	:	:	٠٠.	:	:	:
$H(e_{i_{n-2}})$	Т	T	T		F	F	F
$H(e_{i_{n-1}})$	Т	T	F		T	F	F
$H(e_{i_n})$	Т	F	F		F	Т	F
$H(x_j)$	1	1	1		1	1	0
$\overline{H}(x_j)$	0	0	0		0	0	1

## **Classification of Incident Consequences**

In this paper, there are three main kinds of incident consequences to be considered:

#### · Harm to Humans:

- temporary harm,
- permanent disability,
- fatality.

#### · Environmental Pollution:

- air pollution,
- soil contamination,
- water pollution.

#### · Property Loss:

- damage of materials,
- damage of products,
- damage of equipment.

## **Quantification of Incident Consequences**

· Harm to Humans  $Q_H$ :

If the decision-maker would like to increase the cost of an investment by  $\Delta c$  to reduce the probability of a fatality by  $\Delta p$ ,

$$Q_H = \Delta c / \Delta p$$
.

· Environmental Pollution  $Q_E$ :

The monetary loss of environmental pollution is defined as

$$Q_E = Penalty + Compensation + Harness Cost.$$

· Property Loss  $Q_P$ :

The cost of replacement is used to quantify the loss of property  $Q_P$ , such as the loss of materials, products, and equipment.

## **Calculation of Dynamic Risk**

Due to the following two reasons:

- there is no overlapping between the consequences of any two auxiliary nodes  $x_i$  and  $x_j$ ,  $i \neq j$ ,
- · the auxiliary nodes contain all the consequences of incidents,

the dynamic cybersecurity risk can be defined as

$$\mathscr{R} = \sum_{i=1}^{m'} p(x_i) q(x_i),$$


#### where

- $p(x_i)$  is the occurrence probability of the auxiliary node  $x_i$
- ·  $q(x_i)$  is the monetary loss of the auxiliary node  $x_i$ .




### **Simulation Platform**

The simulation object is a chemical reactor whose control structure is shown as the following figure.




– Legen	d	
HDS	Historical data server	
FS	Engineer station	
G1	Gateway of Ethernet	
G2	Gateway of CANBUS	
G3	Gateway of CANBUS	
PLC1	Controller of V1 and V2	
PLC2	Data collection of P, T and L	
PLC3	Controller of M	
PLC4	Controller of SW	
PLC5	Controller of V4	
PLC6	Controller of V3	
V1	Valve of material	
V2	Valve of another material	
V3	Valve of product	
V4	Valve of pressure reducing	
M	Motor of B	
SW	Switch of H	
Р	Pressure sensor	
T	Temperature sensor	
L	Liquid level sensor	
В	Blender	
Н	Heater	

The simulation platform is implemented in Matlab, which consists of three modules: an evidence generator, an incident prediction module, and a risk assessment module.



The multi-level Bayesian network of the chemical reactor is shown as following figure.



- a, Network Scanning
- a<sub>2</sub> Vulnerability scanning
- $a_3\,$  Buffer overflow attack on HDS
- a<sub>4</sub> FTP attack on HDS
- a<sub>5</sub> Brute force attack on HDS
- a<sub>6</sub> DoS attack on HDS
- a<sub>7</sub> Buffer overflow attack on ES
   a<sub>8</sub> Privilege escalation attack on ES
- a<sub>9</sub> Spoofing attack on ES
- a<sub>10</sub> DoS attack on PLC1
   a<sub>11</sub> DoS attack on PLC2
- a<sub>12</sub> = DoS attack on PLC3
- a<sub>13</sub> DoS attack on PLC4 a<sub>14</sub> - DoS attack on PLC5
- a<sub>15</sub> DoS attack on PLC6
- $a_{16}\,$  Reconfigure PLC1
- $a_{17}$  Reconfigure PLC2  $a_{18}$  Reconfigure PLC3
- a<sub>19</sub> Reconfigure PLC4 a<sub>20</sub> - Reconfigure PLC5
- a<sub>21</sub> Reconfigure PLC6
   a<sub>22</sub> Man-in-the-middle attack on PLC1
- $a_{23}\,$  Man-in-the-middle attack on PLC2
- $a_{24}\,$  Man-in-the-middle attack on PLC3  $a_{25}\,$  Man-in-the-middle attack on PLC4
- a<sub>26</sub> Man-in-the-middle attack on PLC5
   a<sub>27</sub> Man-in-the-middle attack on PLC6
- $r_1$  IP addresses of HDS and ES
- $r_2$  Buffer overflow vulnerability  $r_3$  – FTP server vulnerability
- $r_4$  Login vulnerability
- $r_5$  Buffer overflow vulnerability


- $r_6$  Authentication vulnerability
- $r_7$  Administrator authority of HDS
- $r_8$  Crash of HDS
- $r_9\,$  Administrator authority of ES
- f<sub>1</sub> Traffic control of V1
- $f_2$  Traffic control of V2
- f<sub>3</sub> Traffic control of V3
   f<sub>4</sub> Pressure reducing
- $f_5$  Heating function
- $f_6$  Mixing function  $f_7$  – Liquid level sensation
- $f_0$  = Temperature sensation
- $f_0$  Pressure sensation
- $f_{10}$  Liquid level control  $f_{11}$  Temperature control
- $f_{12}$  Pressure control
- $e_1$  Excessive liquid level  $e_2$  Low liquid level
- $e_3$  Temperature anomaly
- e<sub>4</sub> Excessive pressure
- $e_5$  Heater dry fired  $e_6$  – Reactor explosion
- e<sub>7</sub> Liquid overflow e<sub>8</sub> - Blender stop
- $x_1$  Production damaged
- $x_2$  Tank damaged  $x_3$  - Heater damaged
- $x_4$  Sensors damaged
- $x_5$  Staff<sub>1-4</sub> injured
- $x_6$  Staff<sub>5.9</sub> injured  $x_7$  Water pollution
- $x_8$  Air pollution

The list of evidences is shown as following table.


Start	End	Description	Symbol
50	60	IP sweep	$L(a_1)$
75	110	Vulnerability scanning	$L(a_2)$
120	180	DoS attack to HDS	$L(a_6)$
157	171	IP address spoofing	$L(a_9)$
259	261	Reconfigure PLC5	$L(a_{20})$
266	378	Switch function of V4 failed	$F(f_4)$
286	390	Pressure reduce function failed	$F(f_{12})$
310	400	Pressure is excessive	$H(e_4)$

The quantification of consequences is shown as following table.


Incident Symbol	Description of Incident	Quantification of Consequence(\$)
$x_1$	Product damaged	50,000
$x_2$	Tank damaged	500,000
$x_3$	Heater damaged	10,000
$x_4$	Sensors damaged	10,000
$x_5$	Staff <sub>1-4</sub> injured	800,000
$x_6$	Staff <sub>5-9</sub> injured	1,000,000
$x_7$	Water pollution	200,000
$x_8$	Air pollution	200,000




In the previous simulation, the curve of the cybersecurity risk is shown as the **red** line in the following figure.




To validate the ability to deal with the unknown attacks, the attack knowledge about attack  $\frac{1}{46}$  and attack  $\frac{1}{49}$  is removed from the multilevel Bayesian network.



Then an identical multi-step attack on the system is launched to the system. The new cybersecurity risk curve is shown the dashed line in the following figure.




We repeat the first simulation 5,000 times, and the execution time of 5,000 calculations is recorded. This simulation is run on a machine with Intel Pentium processor G3220 (3M Cache, 3.00GHz) and 4GB DDR3 memory. The following figure shows the distribution of the 5,000 execution times.




Some parameters of the following figure:

- The average execution time of a risk assessment is 94.1ms.
- The minimum execution time of a risk assessment is 89.9ms.
- The maximum execution time of a risk assessment is 131.6ms.




Finally, 25 multi-level Bayesian networks with different node sizes are adopted to show the possible upper/lower bounds and the scalability of our approach.




In the following figure, the fitting line

$$y = 0.0019x - 0.0175$$

matches well with the correlation coefficient r = 0.9987.



This means that the execution time of the risk assessment scales linearly with the increase of the node size of the multi-level Bayesian network.



# Conclusion and Prospect

#### **Conclusion**

- By considering the characteristics of ICSs, a novel multi-level Bayesian network was proposed, which integrated a knowledge of attack, system function, and hazardous incident.
- The attack knowledge and system knowledge were combined to analyze the potential impact of attacks, so the proposed approach had the ability of assessing the risk caused by unknown attacks.
- A unified quantification approach for a variety of consequences of industrial accidents was introduced. Furthermore, the proposed approach could eliminate the error of risk caused by the overlapping amongst hazardous incidents.
- By using a simplified chemical reactor control system in Matlab environment, the designed dynamic risk assessment approach was verified.

### **Prospect**

There are some shortcomings of the proposed risk assessment approach need to be improved.

- · Current research work has no ability for self-learning.
- The sub-second computation time cannot meet some hard realtime systems requirements.

In the future, a dynamic cybersecurity risk assessment, which can automatically adjust the conditional probability and structure of the multi-level Bayesian network by analyzing the real-time data, will be researched, and several approximate inference methods will be attempted in the risk assessment.

# Thank You!

#### Thank You!

You can obtain this slide from my Github: zqmillet@github.com:Presentation.for.Loughborough.University

And I have pushed the code of the simulation to my Github, too. zqmillet@github.com:Multi-level.Bayesian.Network

# Any Questions?