

Building	Method	Energy (kWh)	Per-zone Violation (%)	Comfort MAD (°C, lower=better)	Energy Saving
OfficeSmall (6 zones)	Guided-DiffFNO (ours)	871 ± 2	8.3	0.46 ± 0.01	12.4%
	Diffusion-MLP	994 ± 28	23.8	0.69 ± 0.12	—
OfficeMedium (18 zones)	Guided-DiffFNO (ours)	6985 ± 11	20.5	0.64 ± 0.02	19.2%
	Diffusion-MLP	8645 ± 351	38.0	1.14 ± 0.16	—
SchoolPrimary (25 zones)	Guided-DiffFNO (ours)	6418 ± 18	28.3	0.76 ± 0.01	52.0%
	Diffusion-MLP	13368 ± 1098	68.4	3.06 ± 0.55	—